



**CONSTRUCTION PRODUCTS REGULATION 2011**  
**DECLARATION OF PERFORMANCE**

DoP Number: **DoP\_EEC-0005-02**

Issue: 4

**1. Unique identification code of the product-type:**

9870 Electro-Hydraulic Hold Open Swing Free Door Closer.

**2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4) of the CPR:**

9870.

**3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:**

For use on fire and smoke compartment doors.

**4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):**

EXIDOR LIMITED, PROGRESS DRIVE, CANNOCK, STAFFS, WS11 0JE, UK

**5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):**

N/A

**6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:**

System 1

**7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:**

Standard: EN1155: 1997 + A1: 2002

Notified certification body No.1121.

Certificate of Constancy of Performance: 1121-CPR-AE0005

**8. European Technical Assessment :**

N/A

## 9. Declared performance

Essential characteristics	Performance	Harmonised technical specification
<b>Ability to Release</b>		EN 1155:1997:A1:2002
5.1.2 Release from any angle	Pass	
5.1.3 Not possible to inhibit the release	Pass	
5.1.4 Supply voltage	Pass	
5.1.5 External electrical connection	Pass	
5.1.6 Inlet for external wiring	Pass	
5.2.1 General		
5.2.2 Electrical release	Pass	
5.2.3 Door closing device EN1154 requirements	(see separate DoP 9900 range)	
5.2.4 Durability	25,000 Electrical 25,000 Mechanical	
5.2.5 Angle of hold	>65°	
5.2.6 Manual release	>40 Nm but <120 Nm	
5.2.7 Continues hold open	Pass	
5.2.8 Overload performance	Pass	
5.2.9 Delayed release	Pass	
5.2.10 Electrical performance	Pass	
5.2.11 Temperature rise	Pass	
5.2.12 Damage	Pass	
5.2.13 Fire/smoke doors	Grade 1	
	Pass	
<b>Durability of Self Closing.</b>		
5.2.14.1 Corrosion	Grade 3 (96 Hours)	
5.2.14.2 Corrosion	Pass	
<b>Control of Dangerous substances</b>		
Annex ZA3	PASS	

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:



Robin Darby – Technical Manager  
Date of Issue: 03/02/2016

Exidor Limited  
Progress Drive  
Cannock  
Staffordshire  
WS11 0JE  
United Kingdom