
CERTIFICATE OF APPROVAL

No CF 5193

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

EXIDOR LIMITED

Progress Drive, Cannock, Staffordshire, WS11 OJE

Tel: 01543 578661

Fax: 01543 570050

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

**Exidor 700 Series High
Security Panic & Emergency
Exit Devices**

TECHNICAL SCHEDULE

**TS26 - The Contribution Of
Panic Exit Devices, Operated By
A Horizontal Bar, To The
Performance Of Fire Resisting
Door Assemblies**

**TS31 - The Contribution of
Emergency Exit Devices to the
Performance Of Fire Resistance
of Door Assemblies**

Signed and sealed for and on behalf of CERTIFIRE



Sir Ken Knight
Chairman - Management Council
Page 1 of 4

Issued: 30th August 2013
Valid to: 29th August 2018



CERTIFICATE No CF 5193

EXIDOR LIMITED

Exidor 700 Series High Security Panic & Emergency Exit Devices

1. This approval relates to the following items in the Exidor 700 Series Panic and Emergency Exit Device:

Exidor Panic Exit Device Series 710EC, 710EC/NC, 709EC, 709EC/NC, 701B/30S, 701B/30T, 701BD/30S, 701BD/30T, 702B/30S, 702B/30T, 703B/30S, 703B/30T, 704B/30S, 704B/30T,

Exidor Emergency Exit Device Series 710EC, 710EC/NC, 709EC, 709EC/NC, 701L/30S, 701L/30T, 702L/30S, 702L/30T, 703L/30S, 703L/30T, 704L/30S, 704L/30T, 732L/30S, 732L/30T, 733B/30S & 733B/30T

2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section D of the Technical Standards (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.'

3. This approval relates to the use of the two families of exit devices with the following door assemblies:

Latched and unlatched, door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 60 minutes (Codes ITT and ITC).

Latched and unlatched door assemblies (intumescent sealed or non-intumescent sealed) consisting of metallic faced and edged leaves with cellulosic or mineral cores in steel frames, having a fire resistance of up to 240 minutes (IMM and MM).

4. The exit devices are approved on the basis of:

- i) Initial type testing to EN 179 and EN 1125 for mechanical properties
- ii) Initial type testing to EN 1634-1 for the fire resistance performance of doorsets
- iii) An appraisal against TS26 and TS31
- iv) Certification of quality management system to ISO 9001: 2008.
- v) Inspection and surveillance of factory production control
- vi) On-going audit testing in accordance with EN 179: 2008 and EN 1125:2008

5. This approval is applicable only to the specified exit devices and relevant accessories when used with door assemblies of proven fire resistance (as defined by EN 1634-1 or BS 476: Part 22: 1987). Failure to install the device and accessories in the appropriate manner will invalidate this certificate of approval.

CERTIFICATE No CF 5193
EXIDOR LIMITED

Exidor 700 Series High Security Panic & Emergency Exit Devices

6. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.
7. The following table shows acceptable doorset types and fire resistance periods:

Class	Approved Door Type					
	IMM	MM	TT	ITT	ITM	ITC
FD20	✓	✓	✗	✓	✗	✓
FD30	✓	✓	✗	✓	✗	✓
FD60	✓	✓	✗	✓	✗	✓
FD120	✓	✓	✗	✗	✗	✗
FD240	✓	✓	✗	✗	✗	✗
E 20	✓	✓	✗	✓	✗	✓
EI 20	✓	✓	✗	✓	✗	✓
E 30	✓	✓	✗	✓	✗	✓
EI 30	✓	✓	✗	✓	✗	✓
E 60	✓	✓	✗	✓	✗	✓
EI 60	✓	✓	✗	✓	✗	✓
E 90	✓	✓	✗	✗	✗	✗
EI 90	✓	✓	✗	✗	✗	✗
E 120	✓	✓	✗	✗	✗	✗
EI 120	✓	✓	✗	✗	✗	✗
E 240	✓	✓	✗	✗	✗	✗
EI 240	✓	✓	✗	✗	✗	✗

See CERTIFIRE Technical Schedules for designation of doorset types i.e. IMM etc.

CERTIFICATE No CF 5193
EXIDOR LIMITED

Exidor 700 Series High Security Panic & Emergency Exit Devices

Classification codes

The approval provides the following classifications:

Series 701B/30S, 701B/30T, 701BD/30S, 701BD/30T, 702B/30S, 702B/30T, 703B/30S, 703B/30T, 704B/30S & 704B/30T:

3	7	6	B	1	3	2	1	A	A
---	---	---	---	---	---	---	---	---	---

Series 701L/30S, 701L/30T, 702L/30S, 702L/30T, 703L/30S, 703L/30T, 704L/30S, 704L/30T, 732L/30S, 732L/30T, 733B/30S & 733B/30T:

3	7	6	B	1	3	5	1	A	A/D
---	---	---	---	---	---	---	---	---	-----

Further Information

Further information regarding the details contained in this data sheet may be obtained from Exidor Ltd (Tel: 01543 578661).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).