

Notified body No. 1121
Warrington Certification Limited, Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK

Certificate of Constancy of Performance

1121-CPR-ABB030

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

“Exidor 306 (See ANNEX A) Push Pad” Emergency Exit Devices

Intended use: For use on single and double leaf escape route doors & locked doors on escape routes.

Essential characteristics	Performance	Harmonised technical specification
	Mechanical Test Evidence : 180124 / 188219 / 326789/A Fire Test Evidence : NPD	
Clause 4.2.1 Ability to release (for doors on escape routes) Release function Push pad Single doorset Double doorset Exposed edges and corners Push pad installation Operating element projection Operating element face (Push Pad) Push pad operating gap Test rod Push pad release operation Accessible gap Door free movement Top vertical bolt Keepers Keepers dimensions Door mass and dimensions Outside access device Release forces Security requirement	< 1 sec Pass Pass Pass Pass Z < 250 mm W < 100mm Pass Pass Pass Pass Pass Pass NPD Pass NPD Door mass ≤ 200 Kg, door height ≤ 2440 mm, door width ≤ 1220 mm Pass Type B < 150 N Grade 4	BS EN 179:2008
Clause 4.2.1 Durability of ability to release against aging and degradation (for doors on escape routes) Corrosion resistance Temperature range Covers for vertical rods Lubrication Re-engagement force Durability Abuse resistance – Push Pad Abuse resistance –Vertical rod Final examination	Grade 3 : 96 hours Operating forces at -10 C° and + 60 C° < 50% in excess of the operating forces at +20 C° NPD Lubrication every 20 000 cycles < 50 N Grade 7: 200 000 cycles 500 N & 1000N NPD Type B < 150 N	

Certificate of Constancy of Performance

1121-CPR-ABB030

Clause 4.2.1 Self closing ability C (for fire/smoke doors on escape routes) Re-engagement force	< 50 N	
Clause 4.2.1 Durability of self closing ability C against aging and degradation (for fire/smoke doors on escape routes) Durability Re-engagement force	Grade 7: 200 000 cycles < 50 N	
Clause 4.2.1 Resistance to fire E (integrity) and I (insulation) (for fire doors on escape routes) Suitability of panic exit devices for use on fire resisting doorsets assemblies – Additional requirements	Grade 0: Not Suitable for use on fire/smoke door assemblies.	
Clause 4.1.25 Control of Dangerous substances	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.	

Certificate of Constancy of Performance

1121-CPR-ABB030

Part Number	Description	Single door	Double door	Fire door
ANNEX A				
306	Actuator with Mortice Lock	Yes	Yes	No
306SD	Actuator with Mortice Lock For Steel Doors	Yes	Yes	No
ACCESSORIES				
302EA	Knob Operated Outside Access Device With Euro Aperture (Cylinder Not Supplied)	Yes	Yes	No
302EC	Knob Operated Outside Access Device With Euro Cylinder	Yes	Yes	No
302OA	Knob Operated Outside Access Device With Oval Aperture (Cylinder Not Supplied)	Yes	Yes	No
302OC	Knob Operated Outside Access Device With Oval Cylinder	Yes	Yes	No
302EA/RK	Knob Operated Outside Access Device with key Retention Euro Cylinder Aperture (Cylinder Not Supplied)	Yes	Yes	No
302EC/RK	Knob Operated Outside Access Device with key Retention Euro Cylinder	Yes	Yes	No
302NA	Knob Operated Outside Access Device with No Aperture	Yes	Yes	No
302BA	Knob Operated Outside Access Device with BEST Cylinder Aperture (Cylinder Not Supplied)	Yes	Yes	No
302KA	Knob Operated Outside Access Device with KABA Cylinder Aperture (Cylinder Not Supplied)	Yes	Yes	No
322EA	Lever Operated Outside Access Device With Euro Aperture (Cylinder Not Supplied)	Yes	Yes	No
322EC	Lever Operated Outside Access Device With Euro Cylinder	Yes	Yes	No
CL1	Mechanical Push Button Outside Access Device	Yes	Yes	No
CL2	Mechanical Push Button Outside Access Device With Passage Function	Yes	Yes	No
CL3	Quick Code Mechanical Push Button Outside Access Device	Yes	Yes	No
CL4	Quick Code Mechanical Push Button Outside Access Device With Passage Function	Yes	Yes	No
P3070A	Mortise Keep Plate – Single Door (As supplied with 306 range)	Yes	No	No
P3011	Euro Profile Cylinder 45mm Overall			
P3054	Euro Profile Cylinder 40mm Overall	Yes	Yes	No
RK13	13mm (1/2") Rebate Set (Keep & Rebate Packers)	No	Yes	No
RK25	25mm (1") Rebate Set (Keep & Rebate Packers)	No	Yes	No

Certificate of Constancy of Performance

1121-CPR-ABB030

Produced for

Exidor Limited
Progress Drive, Cannock, Staffordshire, WS11 0JE

and produced in the manufacturing plant

E/002

This is coded form and the information is held by the Notified Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

BS EN 179: 2008

Under system 1 of AVCP are applied and that

the product fulfils all the prescribed requirements set out above

This certificate was first issued on **12/08/2015** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Paul Duggan
Certification Manager
Warrington Certification Ltd

