



---

## CERTIFICATE OF APPROVAL

### No CF 5193

---

This is to certify that, in accordance with  
TS00 General Requirements for Certification of Fire Protection Products  
The undermentioned products of

## EXIDOR LIMITED

**Progress Drive, Cannock, Staffordshire, WS11 OJE**  
**Tel: 01543 578661 Fax: 01543 570050**

Have been assessed against the requirements of the Technical Schedule(s)  
denoted below and are approved for use subject to the conditions  
appended hereto:

---

#### CERTIFIED PRODUCT

**Exidor 700 Series High  
Security Panic & Emergency  
Exit Devices**

#### TECHNICAL SCHEDULE

**TS26 - The Contribution Of  
Panic Exit Devices, Operated By  
A Horizontal Bar, To The  
Performance Of Fire Resisting  
Door Assemblies**

**TS31 - The Contribution of  
Emergency Exit Devices to the  
Performance Of Fire Resistance  
of Door Assemblies**

**Signed and sealed for and on behalf of Exova (UK) Limited trading as  
Warrington Certification**

**Paul Duggan  
Certification Manager**



Issued: 30<sup>th</sup> August 2013  
Reissued: 3<sup>rd</sup> January 2019  
Valid to: 2<sup>nd</sup> January 2024

Page 1 of 4





---

## CERTIFICATE No CF 5193

### EXIDOR LIMITED

---

#### Exidor 700 Series High Security Panic & Emergency Exit Devices

1. This approval relates to the following items in the Exidor 700 Series Panic and Emergency Exit Devices and accessories:

**Exidor Panic Exit Device Series 710EC, 710EC/NC, 709EC, 709EC/NC, 701B/30S, 701B/30T, 701BD/30S, 701BD/30T, 702B/30S, 702B/30T, 703B/30S, 703B/30T, 704B/30S, 704B/30T,**

**Exidor Emergency Exit Device Series 710EC, 710EC/NC, 709EC, 709EC/NC, 701L/30S, 701L/30T, 702L/30S, 702L/30T, 703L/30S, 703L/30T, 704L/30S, 704L/30T, 732L/30S, 732L/30T, 733B/30S & 733B/30T**

2. This certification is provided to the client for its own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
3. This approval relates to the use of the two families of exit devices with the following door assemblies:

**Previously proven unlatched, door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 60 minutes (Codes ITT and ITC).**

**Previously proven unlatched door assemblies (intumescent sealed or non-intumescent sealed) consisting of metallic faced and edged leaves with cellulosic or mineral cores in steel frames, having a fire resistance of up to 240 minutes (IMM and MM).**

4. The exit devices are approved on the basis of:
- i) Initial type testing to EN 179 and EN 1125 for mechanical properties
  - ii) Initial type testing to EN 1634-1 for the fire resistance performance of doorsets
  - iii) An appraisal against TS26 and TS31
  - iv) Certification of quality management system to ISO 9001: 2008.
  - v) Inspection and surveillance of factory production control
  - vi) On-going audit testing in accordance with EN 179: 2008 and EN 1125:2008
5. This approval is applicable only to the specified exit devices and accessories when used with door assemblies of proven fire resistance (as defined by EN 1634-1 or BS 476: Part 22: 1987). Failure to install the device in the appropriate manner will invalidate this certificate of approval.
6. Where these devices are to be fitted to pairs of doors with rebated meeting stiles, this typically represents a more onerous condition compared with plain meeting stile details tested. It is therefore assumed the proposed doorsets have suitable test evidence for rebated meeting stiles.



## CERTIFICATE No CF 5193 EXIDOR LIMITED

### Exidor 700 Series High Security Panic & Emergency Exit Devices

7. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.
8. The following table shows acceptable doorset types and fire resistance periods:

Class	Approved Door Type					
	IMM	MM	TT	ITT	ITM	ITC
FD20	✓	✓	x	✓	x	✓
FD30	✓	✓	x	✓	x	✓
FD60	✓	✓	x	✓	x	✓
FD120	✓	✓	x	x	x	x
FD240	✓	✓	x	x	x	x
E 20	✓	✓	x	✓	x	✓
EI 20	✓	✓	x	✓	x	✓
E 30	✓	✓	x	✓	x	✓
EI 30	✓	✓	x	✓	x	✓
E 60	✓	✓	x	✓	x	✓
EI 60	✓	✓	x	✓	x	✓
E 90	✓	✓	x	x	x	x
EI 90	✓	✓	x	x	x	x
E 120	✓	✓	x	x	x	x
EI 120	✓	✓	x	x	x	x
E 240	✓	✓	x	x	x	x
EI 240	✓	✓	x	x	x	x

**Key:**

- ✓ - approved  
x - Not approved



**CERTIFICATE No CF 5193**  
**EXIDOR LIMITED**

**700 Series High Security Panic & Emergency Exit Devices**

10. Doors are classified as the following types:

**Type MM** - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that do not contain intumescent materials in the frame to leaf gap.

**Type IMM** - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that contain intumescent materials in the frame to leaf gap.

**Type ITT** - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in timber frames

**Type ITM** - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in metal frames.

**Type ITC** - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

**Classification Codes**

The approval provides the following classifications:

**Series 710EC, 710EC/NC, 709EC, 709EC/NC, 701B/30S, 701B/30T, 701BD/30S, 701BD/30T, 702B/30S, 702B/30T, 703B/30S, 703B/30T, 704B/30S, 704B/30T:**

3	7	6	B	1	3	2	1	A	A
---	---	---	---	---	---	---	---	---	---

**Series 710EC, 710EC/NC, 709EC, 709EC/NC, 701L/30S, 701L/30T, 702L/30S, 702L/30T, 703L/30S, 703L/30T, 704L/30S, 704L/30T, 732L/30S, 732L/30T, 733B/30S & 733B/30T:**

3	7	6	B	1	3	5	1	A	A/D
---	---	---	---	---	---	---	---	---	-----

**Further Information**

Further information regarding the details contained in this data sheet may be obtained from Exidor Ltd (Tel: 01543 578661).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).